

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1288:154 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Gamewell, 60 Pleasant Street, Ashland, MA 01721
Contact: *Brian Reynolds (203) 484-1200 *FAX (203) 484-7309

DESIGN: Model *IdentiFlex* 610, 610VE and IF610 fire alarm control units. Power-limited, automatic, manual, coded, noncoded; local, auxiliary and remote station (Protected Premise Unit), central station, waterflow and sprinkler supervisory service. Refer to the listee's data sheet for detailed product description and operational considerations System components:

610, 610VE, IF610	Control Units
31025	Bus driver Module
31067	Processor Board
31021, 31022, 31031	610 Analog Addressable Module
LP-864	Line Protector
30952	SIM-232
30996	Network Card
31024	Display Card
EVX-25, -25E, -50, -50E	Audio Amplifier
EVX-4Z, -2ZA	Zone Splitter
UDACT	Digital Dialer

RATINGS: 120V 60Hz, 50Hz, 2A - Primary
24V dc nominal battery voltage - Secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition

NOTE: For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

*Rev. 05-28-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager